

# **GENERAL CONDITIONS FOR POTASSIUM PERMANGANATE**

## **I. CONTRACT PERIOD**

The period of this contract will be for **Ninety (90) Days** from date bid is awarded. This contract may be renewed for up to a total of **THREE (3) Years** from the initial award date upon the agreement of both parties. Bid price will remain firm during the period of the contract.

## **II. DELIVERY**

Deliveries shall be made within seven (7) working days from the date of order. The vendor shall notify Water Plant Operator or Shelby County Water Services personnel (the person who ordered the product) of any problems in meeting the mandatory seven (7) working day deadline and the vendor must schedule specific delivery day and time with personnel if the deadline is not met. Excessive failure to deliver within seven (7) working days shall be grounds for rejection of the vendor for future purchases, at the sole discretion of Shelby County. Bulk deliveries of chemicals, if ordered, shall be made in tanker truck. For all chemical deliveries, the truck must be equipped with all the means to safely convey the chemical from the truck to the storage tanks. Any spillage or leakage shall be the responsibility of the vendor.

All quoted prices shall include delivery charges. Deliveries shall be made to the following addresses:

Shelby County South Water Treatment Plant  
7935 Highway 61  
Wilsonville, Alabama 35186

Talladega/Shelby Water Treatment Plant  
289 First Road  
Alpine, Alabama 35014

## **III. CHEMICAL DELIVERIES**

Deliveries of totes and/or bulk shall be made to either of the water treatment plants in accordance with plant operator instructions at the Talladega/Shelby Water Treatment plant located near Childersburg and at the Shelby County South Water Treatment Plant located in Wilsonville. Orders may include one or more delivery sites.

For all bulk loads of chemicals, supplier shall provide all necessary hoses and fittings to safely offload the product into the designated tanks by plant personnel. Prior to first delivery, supplier needs to visit site to understand the layout and what hoses and fittings will be needed for deliveries.

Drivers shall not make connections nor initiate offloading procedures until authorized to do so by the plant operators. Drivers will be required to wear protective clothing and equipment in accordance with OSHA rules during unloading of the product. Driver will monitor unloading to insure that delivery is discontinued if a problem during unloading develops.

The supplier shall be responsible for cleanup of any spills resulting from the delivery or occurring during unloading of the product.

#### **IV. BILLING**

Invoice payments shall be based solely on quantity of items received and the vendors stated bid price. Product shall be billed in **per container** and all prices shall include shipping. Shelby County Water Services does require a Purchase Order for every order placed. Shelby County Water Services is tax exempt (tax exempt #63-6001694). All invoices shall be billed to:

Shelby County Water Services  
P.O. Box 10  
Columbiana, Alabama 35051

#### **V. ESTIMATED ANNUAL USE**

Products will be ordered on an *AS NEEDED* basis. Minimum quantities for chemical orders, other than bulk orders, may be one (1) tote or one (1) pallet. Estimated quantities for product are:

- 10,000 to 12,000 pounds per year

#### **VI. BID QUALIFICATIONS**

All BIDDERS must submit product information with bids. Information to be submitted must show the product proposed meets all the specifications listed below and list **ALL EXCEPTIONS** to the specifications in a separate document.

# QUOTATION SHEET

## Shelby County Water Services

**BID: POTASSIUM PERMANGANATE**

Price per 25 kg (55.115 lb) Container Delivered: \$\_\_\_\_\_ per container

Number of Containers per Pallet \_\_\_\_\_

**THE UNDERSIGNED OFFERS THESE PRICES, TERMS, AND DELIVERY AS PER BID  
GENERAL CONDITIONS AND SPECIFICATIONS:**

NAME OF COMPANY: \_\_\_\_\_

BY: (Please Print): \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

COMPANY ADDRESS: \_\_\_\_\_

\_\_\_\_\_

PHONE: \_\_\_\_\_

E-MAIL: \_\_\_\_\_

**BIDS SUBMITTED ARE FIRM AND NO CLAIMS FOR ERRORS WILL BE MADE AFTER  
BIDS ARE OPENED AND SUBSEQUENT THEREOF.**

Sworn to and subscribed before me this

the \_\_\_\_\_ day of \_\_\_\_\_, \_\_\_\_\_.

\_\_\_\_\_, Notary Public

My Commission Expires: \_\_\_\_\_

# **BID SPECIFICATIONS FOR POTASSIUM PERMANGANATE**

## **GENERAL**

Must be Free-Flowing Grade and conform to AWWA Standard B603 – Latest Edition. This material must be certified as suitable for contact with or treatment of drinking water by an accredited certification organization in accordance with ANSI/NSF Standard 60, Drinking Water Treatment Chemicals – Health Effect. Product must be acceptable to the Alabama Department of Environmental Management for use in drinking water.

## **CHEMICAL AND PHYSICAL DATA**

FORMULA	KMnO <sub>4</sub>
FORMULA WEIGHT	158.034
FORM	Granular Crystalline
SPECIFIC GRAVITY	1.0414 by weight, 15°C/4°C 6% Solution
BULK DENSITY	Approximately 100 lb/ft <sup>3</sup>
HEAT OF SOLUTION	10.2 Kilocalories/mole (16% in 700 moles of water)
MINIMUM CONTENT	KMnO <sub>4</sub> – 97 percent by weight

Bidders shall include with their bids certified analysis of proposed product showing compliance with the above performance and quality specifications.

## **PACKAGING**

Containers must have full open top single-trip drums and meet appropriate DOT standards. Containers must be constructed of 24-gauge steel and tapered to allow nested storage of empty drums. Containers must also have a lever lock lid.

Must come packaged as follows:  
25 kg (55.115 lb) net