



## **Water Services Building Project**

### **ADDENDUM NO. 3**

Date: May 10, 2023

RE: Water Services Building Project Bid

BID DATE AND TIME:

Thursday, May 11, 2023 at 2:00 p.m. CST

Location for the bid opening remains the Shelby County Manager's Office, located at 200 West College Street, Room 123, Columbiana, Alabama, 35051

\*\*\*\*\*

#### **Substitution Request:**


- 26 5000 Lighting Materials and Methods 2.4 Manufacturers – Lithonia Lighting CPX LED Panels – APPROVED
- 26 5000 Lighting Materials and Methods 2.4 Manufacturers – Metalux LED Panels – NOT APPROVED

#### **Questions and Clarifications:**

Q1 – What materials is to be used for the fencing and rolling gate at the Fencing Area 125 below the mechanical mezzanine.

A1 - Galvanized 8 gauge wire chain link mesh and schedule 40 galvanized steel pipe shall be used.

Q2 - Please clearly the interior elevations of the windows/storefront in the Break & Training Room 121 and provide an elevation detail of this window.  
A2 – See detail below.



Q3 – Does the windows/storefront in the Break & Training Room 121 require window treatments of any kind?  
A3 – Yes, please provide manual shades and brackets to match other locations shown on A8.

End of Addendum