



Water Services Building Project

ADDENDUM NO. 5

Date: May 10, 2023

RE: Water Services Building Project Bid

BID DATE AND TIME:

Thursday, May 11, 2023 at 2:00 p.m. CST

Location for the bid opening remains the Shelby County Manager's Office, located at 200 West College Street, Room 123, Columbiana, Alabama, 35051

Questions and Clarifications:

Q1 – What part of the water service is the contractor responsible for?

A1 - The Contractor is responsible for material and labor associated with the water service from the discharge side of the meter to the building including providing a 1-inch Watts 007 Backflow Preventer. The Owner will provide all material and labor associated with excavation and installation of water main tap, piping from main to the meter, pressure regulator, meter, and meter box.

Q2 – Is there a form for submitting the Accounting of Sales Tax to include with the proposal showing the tax savings?

A2 - We will be using the tax exemption certificate method described in the project manual and a Form STC-1, Sales and Use Tax Certificate of Exemption for Governmental Entity Projects will be used after the owner and contractor submit a completed Form ST: EXC-01. This project does not have to be reviewed by DCM so the accounting of sales tax Form C-3A is not required or needed for this project.

Q3 - Section 06 4100 Architectural Wood Casework 1.4 Quality Assurance A.2 requires fabricator to be Certified under AWI Quality Certification Program. Can this certification requirement be waived if the millwork subcontractor builds the cabinets to AWI standards?

A3 – If the proposed casework subcontractor meets the requirements of Section 00-0201 Instructions to Bidders 1.5 Bids C. Proof of Competency of Bidder by providing satisfactory evidence that the proposed subcontractor has sufficient experience to perform the work, yes the AWI Quality Certification Program requirement may be waived.

End of Addendum