



Shelby County Generators Bid

ADDENDUM NO. 1

Date: September 28, 2023

RE: Shelby County Generators Bid

BID DATE AND TIME:

Tuesday, October 3, 2023 at 2:30 p.m.

Location for the bid opening remains the Shelby County Manager's Office, located at 200 West College Street, Room 123, Columbiana, Alabama, 35051

Questions and Clarifications:

Q1: Will they require a NG engine or LP engine? The specs did not mention which fuel they specifically are planning on utilizing.

A1: LP

Q2: Prime or Standby?

A2: Standby

Q3: Is startup needed?

A3: Yes

Q4: Is load banking needed?

A4: No

Q5: For the ATS, what will be the mechanism? (Standard, bypass, or service entrance)

A5: Standard

Q6: For the ATS, what will be the transition? (standard, programmed, or closed)

A6: Standard

Q7: Do you have a forklift or loading dock at the receiving facility?

A7: Yes

Q8: Do you require offloading?

A8: No