



## **Shelby County Jail Roof Replacement Project**

### **ADDENDUM NO. 2**

Date: December 16, 2025

RE: Shelby County Jail Roof Replacement Project

#### **BID DATE AND TIME:**

Thursday, December 18, 2025 at 2:00 p.m.

Location for the bid opening remains the office of the Shelby County Chief Financial Officer, located at 200 West College Street, Room 125, Columbiana, Alabama, 35051

\*\*\*\*\*

#### **General:**

None

#### **Project Manual, Plans and Specifications:**

- See attached additional detail for Section 07-5419 – Expansion Joint Wall Detail  
Where this condition exists, the following shall be required:
  - Remove the existing expansion joint coping on the parapet wall
  - Install new backer rod in the expansion joint
  - On the main jail roof section, Install the new wall flashing membrane up the parapet wall and terminate at the expansion joint
  - On the main jail roof section, Install the new wall flashing membrane up the parapet wall and terminate at the expansion joint
  - On the main jail roof section, Install the new wall flashing membrane up the parapet wall and terminate at the expansion joint


#### **Substitution Request:**

None

#### **Clarifications:**

None

## TYPICAL INSTALLATION



- Remove the existing expansion joint coping on the parapet wall
- Install new backer rod in the expansion joint
- On the main jail roof section, Install the new wall flashing membrane up the parapet wall and terminate at the expansion joint
- On the main jail roof section, Install the new wall flashing membrane up the parapet wall and terminate at the expansion joint
- On the main jail roof section, Install the new wall flashing membrane up the parapet wall and terminate at the expansion joint