

GENERAL CONDITIONS FOR HDPE AND ACCESSORIES MARCH 2026

I. CONTRACT PERIOD

The period of this contract will be for **one hundred eighty (180) days** from the date the bid is awarded. This contract may be renewed for up to **three (3) years** from the initial award date upon the agreement of both parties. The bid price will remain firm during the period of the contract.

II. DELIVERY

Deliveries shall be made within seven (7) working days from the order date. The vendor shall notify Water Plant Operator or Shelby County Water Services personnel (the person who ordered the product) of any problems in meeting the mandatory seven (7) working day deadline. The vendor must schedule a specific delivery day and time with personnel if the deadline is not met. Excessive failure to deliver within seven (7) working days shall be grounds for rejection of the vendor for future purchases at the sole discretion of Shelby County.

All quoted prices shall include delivery charges. Deliveries shall be made to the following locations:

**Shelby County Field Operations Office
10927 US Highway 280
Sterrett, AL 35147**

**Shelby County Booster Station B-2-N
10610 Old Hwy 280
Sterrett, AL 35147**

III. BILLING

Billing and payments shall be based solely on the quantity of items received, noted on the receiving ticket, and the vendor's stated bid price. **The product shall be billed based on the signed receiving ticket for items received, and all prices shall include shipping.** Shelby County Water Services requires a Purchase Order for every order placed. Shelby County Water Services is tax-exempt.

All invoices shall be billed to:

**Shelby County Water Services
10927 US Highway 280
Sterrett, AL 35147**

ap-water-landfill@shelbyal.com - preferred delivery method

IV. **ESTIMATED ANNUAL USE**

Products will be ordered on an **AS-NEEDED** basis.

V. **BID QUALIFICATIONS**

All BIDDERS must submit product information with bids. Information to be submitted must show that the product proposed meets all the specifications listed in the Bid Specifications and list **ALL EXCEPTIONS** to the specifications in a separate document. Failure to submit these exceptions may be cause for disqualification.

BID SPECIFICATIONS FOR HDPE AND ACCESSORIES

- I. All HDPE pipe must comply with one of the following standards:
 - a. AWWA C901-20, Polyethylene (PE) Pressure Pipe and Tubing, $\frac{3}{4}$ In. (19 mm) Through 3 In. (76 mm), for Water Service.
 - b. AWWA C906-21, Polyethylene (PE) Pressure Pipe and Fittings, 4 In. Through 65 In. (100 mm through 1,650 mm), for Waterworks.