THE SHELBY COUNTY COMMISSION
CUSTOM REACTIVATION AND/OR VIRGIN REPLACEMENT OF GRANULAR ACTIVATED CARBON (GAC) MEDIA AT TALLADEGA/SHELBY WATER TREATMENT PLANT

ADDENDUM NO. 1

DATE: **November 25, 2026**

RE: **Revision and Clarification to the subject Solicitation for Bids**

QUESTIONS:

1. **Q:** Is a bidder permitted to submit a quotation for only one product?
   A: Yes.

2. **Q:** Can a product datasheet for RX 400 GAC be provided?
   A: No. On Part 2 Products 2.1.B. the solicitation for bids specifies the product characteristics that are required of a custom reactivated carbon product. The RX 400 GAC, formerly known as CMR Filtrasorb 400 GAC, is used as reference to describe the required process, product quality included in removing the spent 12x40 Filtrasorb GAC from the subject community drinking water treatment plant (WTP), which includes storing separately from all other carbon products, thermally reactivating to the product specification indicated in Section 2.1.B, and reinstalling at that same WTP when scheduled by OWNER.