THE SHELBY COUNTY COMMISSION
CUSTOM REACTIVATION AND/OR VIRGIN REPLACEMENT OF GRANULAR ACTIVATED CARBON (GAC) MEDIA AT SHELBY COUNTY SOUTH WATER TREATMENT PLANT

ADDENDUM TO THE PLANS AND SPECIFICATION-CONTRACTUAL DOCUMENTS

ADDENDUM NO. 1

DATE: **November 25, 2026**

RE: **Revision and Clarification to the subject Solicitation for Bids**

REVISIONS:

1. **The BID FORM is revised as highlighted below.**

Line Item	Estimated Annual Deliveries (2,775 cu. ft. each)	Estimated Annual Volume (cu. ft.)	Unit Price ($/cu. ft.)	Total Per Line Item ($)	Lead time from when order is placed (Days)
Delivery, Installation of RX 400 GAC Media including up to 15% Virgin makeup. Removal, transportation, storage of one 2,775 cu. ft. spent swing load.	2	5,500			
Delivery, Installation of Virgin F400 GAC Media. Removal, transportation, storage of one 2,775 cu. ft. spent swing load.	3	8,325			
Delivery Totals	5	13,825	**Annual $**		

Additive Alternate	Unit Price
Lump Sum for pH adjustment of media at Manufacturer's facility (Not at WTP)	**($ per 2,775 cu. ft. delivery)**
Unit Price for Additional Virgin GAC above the included 15% makeup.	**($ per cu. ft. virgin makeup)**
Lump Sum for Disposal of one 2,775 cu. ft. spent load, unsuitable for industrial resale.	**($ per approx. 2,775 cu. ft. disposal cost)**

QUESTIONS:

1. **Q:** Is a bidder permitted to submit a quotation for only one product?
   A: Yes.

2. **Q:** Can a product datasheet for RX 400 GAC be provided?
   A: No. On Part 2 Products 2.1.B. the solicitation for bids specifies the product characteristics that are required of a custom reactivated carbon product. The RX 400 GAC, formerly known as CMR Filtrasorb 400 GAC, is used as reference to describe the required process, product quality included in removing the spent 12x40 Filtrasorb GAC from the subject community drinking water treatment plant (WTP), which includes storing separately from all other carbon products, thermally reactivating to the product specification indicated in Section 2.1.B, and reinstalling at that same WTP when scheduled by OWNER.