

# **GENERAL CONDITIONS FOR COPPER TUBING – PVC PIPE**

## **I. CONTRACT PERIOD**

The period of this contract will be for Ninety (90) Days from date bid is awarded. This contract may be renewed for up to Three (3) Years from the initial award date upon the agreement of both parties. Bid price will remain firm during the period of the contract.

## **II. DELIVERY**

Deliveries shall be made within seven (7) working days from the date of order. The vendor shall notify Water Plant Operator or Shelby County Water Services personnel (the person who ordered the product) of any problems in meeting the mandatory seven (7) working day deadline and the vendor must schedule specific delivery day and time with personnel if the deadline is not met. Excessive failure to deliver within seven (7) working days shall be grounds for rejection of the vendor for future purchases, at the sole discretion of Shelby County.

All quoted prices shall include delivery charges. Deliveries shall be made to the following addresses:

Shelby County Booster Station B-2-N  
10610 Old Hwy. 280  
Chelsea, AL 35043

Shelby County Field Operations Office  
42 Big Oak Circle  
Sterrett, AL 35147

## **III. BILLING**

Invoice payments shall be based solely on quantity of items received and the vendors stated bid price. Product shall be billed by items received and all prices shall include shipping. Shelby County Water Services does require a Purchase Order for every order placed. Shelby County Water Services is tax exempt (tax exempt #63-6001694).

All invoices shall be billed to:

Shelby County Water Services  
200 West College Street, Room 145  
Columbiana, AL 35051  
[ap-water-landfill@shelbyal.com](mailto:ap-water-landfill@shelbyal.com)

#### **IV. ESTIMATED ANNUAL USE**

Products will be ordered on an *AS NEEDED* basis. Estimated quantities for products are:

See attached bid documents for quantities.

#### **V. BID QUALIFICATIONS**

All BIDDERS must submit product information with bids. Information to be submitted must show the product proposed meets all the specifications listed below and list **ALL EXCEPTIONS** to the specifications in a separate document.

# QUOTATION SHEET

## Shelby County Water Services

### BID: COPPER TUBING – PVC PIPE

VENDOR NAME:					
Bid Items	Make or Manufacturer	Model #	Price Each Delivered (Per Foot), \$	Estimated Annual Quantity Needed	Extended Total \$
¾" Type K Soft Copper Tubing (60' or 100' Coils), per foot				1,500	
1" Type K Soft Copper Tubing (60' or 100' Coils), per foot				3,000	
2" Type K Soft Copper Tubing (60' or 100' Coils), per foot				300	
2" PVC Pipe, 250 psi, DR17, IPS, Slip Joint, per foot				500	
3" PVC Pipe, 250 psi, DR17, IPS, Slip Joint, per foot				300	
4" PVC Pipe, 250 psi, DR17, IPS, Slip Joint, per foot				500	
6" PVC Pipe, 250 psi, DR17, IPS, Slip Joint, per foot				500	
8" PVC Pipe, 250 psi, DR17, IPS, Slip Joint, per foot				100	
10" PVC Pipe, 250 psi, DR17, IPS, Slip Joint, per foot				100	
TOTAL					

**Shelby County Water Services**  
**BID: COPPER TUBING – PVC PIPE**

**THE UNDERSIGNED OFFERS THESE PRICES, TERMS, AND DELIVERY AS PER BID  
GENERAL CONDITIONS AND SPECIFICATIONS:**

**NAME OF COMPANY:** \_\_\_\_\_

**BY: (Please Print):** \_\_\_\_\_

**SIGNATURE:** \_\_\_\_\_

**COMPANY ADDRESS:** \_\_\_\_\_

\_\_\_\_\_

**PHONE:** \_\_\_\_\_

**E-MAIL ADDRESS:** \_\_\_\_\_

**BIDS SUBMITTED ARE FIRM AND NO CLAIMS FOR ERRORS WILL BE MADE AFTER  
BIDS ARE OPENED AND SUBSEQUENT THEREOF.**

Sworn to and subscribed before me this

the \_\_\_\_\_ day of \_\_\_\_\_, \_\_\_\_\_.

\_\_\_\_\_, Notary Public

My Commission Expires: \_\_\_\_\_

**QUOTATION SHEET 2 of 2**

## **BID SPECIFICATIONS FOR COPPER TUBING – PVC PIPE**

### **I. Copper Tubing**

Copper tubing for underground service shall be Type K annealed, ANSI/ASTM B88. Copper tubing shall be NSF 61 certified for drinking water.

### **II. PVC Pipe**

Pipe supplied with a gasketed joint shall meet the requirements of ASTM D-3139, and the joint gasket shall conform to the requirements of ASTM F-477. All pipe for water service shall meet the requirements of NSF Standard #14, "Plastic Piping and Components and Related Materials," and Standard #61, "Drinking Water System Components – Health Effects". The pipe shall display the "NSF-PW" listing mark signifying use in potable water applications.