

ADDENDUM NUMBER 1

3" FIRE HYDRANT METERS LEAD-FREE STANDARDS FOR SHELBY COUNTY WATER SERVICES

1. Revisions to Bid Specifications

1.1 The following revisions are hereby added as Addendum No. 1 to the referenced Bid Specifications and shall be considered when preparing bids.

1.2 Section 4 – METER CONSTRUCTION

1.2.1 Revision to Item B: Include a check valve on the outlet side of the meter with a 2" gate valve and a standard brass male hose coupling.

2. Acknowledgement

2.1 Receipt of Addendum No. 1 shall be acknowledged by:

2.1.1 Noting on the Bid Proposal Page "Addendums Received: 1"

3. Conclusion

3.1 This is the end of Addendum Number 1, dated June 2, 2021.



Michael Cain, P.E.